

QUALITY-CERTIFICATE

Test Report No.: WM-907-2012

Manufacturer of PVC-Floor Coverings:	ITEC contract floors	
Seam Welding:	PVC-Cold Welding Liquid Type A Werner Müller GmbH closely cut seam	
Test:	<i>Seam Tensile Strength according to DIN EN 684</i>	
Results:	<i>All weldings fulfill the requirements according to DIN EN 649.</i>	
	<i>Mean Value</i>	
	<i>Seam Tensile Strength [N/50 mm]</i>	
PVC-Floor Coverings:	Requested Value	Actual Value
ITEC Atom:	240	363
ITEC Concept:	240	350
ITEC Penta:	240	340
ITEC Silento:	240	269



iff-Institut für Fußbodenbau

Overath (Germany), August 2012

Torsten Grotjohann

Management of the institute: Torsten Grotjohann

