

# QUALITY-CERTIFICATE

Test Report No.: WM-907-2012

<b>Manufacturer of PVC-Floor Coverings:</b>	ITEC contract floors	
<b>Seam Welding:</b>	PVC-Cold Welding Liquid Type A Werner Müller GmbH closely cut seam	
<b>Test:</b>	<i>Seam Tensile Strength according to DIN EN 684</i>	
<b>Results:</b>	<i>All weldings fulfill the requirements according to DIN EN 649.</i>	
	<i>Mean Value</i>	
	<i>Seam Tensile Strength [N/50 mm]</i>	
<b>PVC-Floor Coverings:</b>	<b>Requested Value</b>	<b>Actual Value</b>
ITEC Atom:	240	363
ITEC Concept:	240	350
ITEC Penta:	240	340
ITEC Silento:	240	269



iff-Institut für Fußbodenbau

Overath (Germany), August 2012

*Torsten Grotjohann*

Management of the institute: Torsten Grotjohann

